

June 18, 2019

To: All Bidders

From: Kate Bailey
Director of Procurement

Re: ADDENDUM NO. 2
19-048.2 – Heating System Renovation at Port Administration Building

This Addendum No. 2 is issued to:

1. Provide a response to the following question received:

Q1: I represent GP Energy Products in Broomall, PA. I am requesting permission to bid our Thermal Solutions AMP-1000 Water-Tube Boilers on the Heating System Renovation at Port Administration Building Project in Philadelphia, PA. The AMP Boiler has a unique compact design while being fully serviceable and accessible to critical internal components while being competitive with industry standard Fire-tube Boilers.

A1: While the boiler has similar capacity and performance characteristics, due to space consideration within the existing boiler room we cannot accept this as an alternative. Using the two boiler concept, there is not enough space for side by side or stacking with considering hot water pipe distribution and vent size/routing.

All other terms and conditions remain unchanged.

Bidders shall acknowledge receipt of this addendum by immediately faxing a copy of the completed acknowledgment to Kate Bailey at 215-426-6800 or email procurement@philaport.com

ACKNOWLEDGMENT OF RECEIPT OF ADDENDUM NO. 2
Heating System Renovation at Port Administration Building
Project 19-048.2

Date _____

By _____

Company _____

Telephone _____

Fax _____

Email _____