

October 19, 2022

To: All Bidders

From: Kate Bailey
Director of Procurement

Re: **ADDENDUM NO. 5**
22-028.6 – Pier 78 Annex Fire Sprinkler System Upgrades

This Addendum is issued to:

1. Respond to the following question received:

Q1: On plan it call for replacing 7 Alarm devices , but on breakout paper it indicates replace all alarm devices. Please advise.

A1: Remove damaged fire alarm devices and replace and/or install new alarm devices per Plans.

All other terms and conditions remain unchanged.

Bidders shall acknowledge receipt of this addendum by immediately emailing a copy of the completed acknowledgment to Kate Bailey at procurement@philaport.com

ACKNOWLEDGMENT OF RECEIPT OF ADDENDUM NO. 5

Project #22-028.6

Pier 78 Annex Fire Sprinkler System Upgrades

Date _____

By _____

Company _____

Telephone _____

Fax _____

Email _____